



HospitalityLawyer.com[®]
worldwide legal, safety and security solutions

Terms and Conditions for Forms, Checklists, and Procedures

Forms, checklists, and procedures at HospitalityLawyer.com[®] are provided as informational, educational, and illustrative purposes only. HospitalityLawyer.com[®] does not render legal advice. You should always consult legal professionals for your specific needs, questions, and services. If you choose to use a form, checklist, or procedure, you do so at your own risk. HospitalityLawyer.com[®] does not make any representations that the forms, checklists, or procedures are suitable for a particular use and the user should always independently assure themselves of the accuracy and legal compliance for their particular jurisdiction.

Fire Prevention Checklist

Mark with a Y or N to indicate if the requirements are met or not.

- Fire extinguishers - Are charged and their inspection tags are current.
- Lighting system – All lights are operable.
- Lighting system – If any ballasts are defective, they should be immediately replaced – train staff to look for these issues and to report them.
- Gas hoses – In good condition with no noticeable stress points or burn marks. Their fittings are secured.
- Water heater/Boiler – The area around these is clear – nothing is stored within the safe radius.
- Electrical panels – Nothing is stored within a 3 foot radius.
- Fire/smoke alarms – Operational and inspected regularly.
- Security systems – Are functioning.