



## **Terms and Conditions for Forms, Checklists, and Procedures**

Forms, checklists, and procedures at HospitalityLawyer.com are provided as informational, educational, and illustrative purposes only. HospitalityLawyer.com does not render legal advice. You should always consult legal professionals for your specific needs, questions, and services. If you choose to use a form, checklist, or procedure, you do so at your own risk. HospitalityLawyer.com does not make any representations that the forms, checklists, or procedures are suitable for a particular use and the user should always independently assure themselves of the accuracy and legal compliance for their particular jurisdiction.

## ADA Title III “Quick Look” Barriers Checklist

---

This checklist is designed to give businesses a quick appraisal of potential problem areas for accessibility. For detailed review standards contact the Architectural and Transportation Barriers Compliance Board at 1-800-872-2253 and/or obtain a copy of the Uniform Federal Accessibility Standards for current specifications.

### ITEMS TO BE PERFORMED

---

#### Building Access

	YES	NO
1. Are 96-inch-wide parking spaces designated with a 60-inch access aisle?	<input type="checkbox"/>	<input type="checkbox"/>
2. Are parking spaces near main building entrance?	<input type="checkbox"/>	<input type="checkbox"/>
3. Is there a “drop off” zone at building entrance?	<input type="checkbox"/>	<input type="checkbox"/>
4. Is the gradient from parking to building entrance 1:12 or less?	<input type="checkbox"/>	<input type="checkbox"/>
5. Is the entrance doorway at least 32 inches?	<input type="checkbox"/>	<input type="checkbox"/>
6. Is door handle easy to grasp?	<input type="checkbox"/>	<input type="checkbox"/>
7. Is door easy to open (less than 8 lbs pressure)?	<input type="checkbox"/>	<input type="checkbox"/>
8. Are other than revolving doors available?	<input type="checkbox"/>	<input type="checkbox"/>

#### Building Corridors

	YES	NO
1. Is path of travel free of obstruction and wide enough for a wheelchair?	<input type="checkbox"/>	<input type="checkbox"/>
2. Is floor surface hard and not slippery?	<input type="checkbox"/>	<input type="checkbox"/>
3. Do obstacles (phones, fountains) protrude no more than 4 inches?	<input type="checkbox"/>	<input type="checkbox"/>
4. Are elevator controls low enough (48 in) to be reached from wheelchair?	<input type="checkbox"/>	<input type="checkbox"/>
5. Are elevator markings in Braille for the blind?	<input type="checkbox"/>	<input type="checkbox"/>
6. Does elevator provide audible signals for the blind?	<input type="checkbox"/>	<input type="checkbox"/>
7. Does elevator interior provide a turning area of 51 inches for wheelchairs?	<input type="checkbox"/>	<input type="checkbox"/>

#### Restrooms

	YES	NO
1. Are restrooms near building entrance/personnel office?	<input type="checkbox"/>	<input type="checkbox"/>
2. Do doors have lever handles?	<input type="checkbox"/>	<input type="checkbox"/>
3. Are doors at least 32 inches wide?	<input type="checkbox"/>	<input type="checkbox"/>
4. Is restroom large enough for wheelchair turnaround (51 inches minimum)?	<input type="checkbox"/>	<input type="checkbox"/>
5. Are stall doors at least 32 inches wide?	<input type="checkbox"/>	<input type="checkbox"/>

6. Are grab bars provided in toilet stalls?		
7. Are sinks at least 29 inches high with room for a wheelchair to roll under?		
8. Are sink handles easily reached and used?		
9. Are soap dispensers, towels, no more than 48 inches from floor?		

**Personnel Office**

YES NO

1. Are doors at least 32 inches wide?		
2. Is the door easy to open?		
3. Is the threshold no more than ½ inch high?		
4. Is the path of travel between desks, tables wide enough for wheelchairs?		